



National Urban Health Mission

GOVERNMENT OF TRIPURA
MADHYAPRATAPGARH URBAN PRIMARY HEALTH CENTRE
AMC WARD NO. 41, AGARTALA, WEST TRIPURA

NO - F (32) MOI/C/MPUPHC/School/2022 - 1419

Dated:-05/09/2024

Safe Drinking Water, Health & Hygiene Certificate

Ref.No.4(05)/Principal/2023-24/152 dated:04-09-2024

It is certified that a combine inspection team headed by Medical Officers form Madhya Pratapgarh UPHC, AMC Ward No-41, Agartala, Tripura West inspected the premises Kabiraj Tilla H.S. School Netaji Palli Badharghat on 05/09/2024 and found that Kabiraj Tilla H.S. School has safe drinking water facilities for the students and staff members of the said institution is maintaining of hygienic sanitation conditions in the school, in the building & campus as per norms. Hope this will be sustained further.

The above certificate is valid for one year.

Shashin
05/09/2024

Medical officer In-charge
Madhya Pratapgarh UPHC
Agartala, Tripura(West)

Medical Officer In-charge
Madhya Pratapgarh Urban
Primary Health Centre,
A.M.C., Ward No-41

To
The Headmistress
Kabiraj Tilla H.S. School
Netajipalli, Badharghat, Agartala

Office of the Assistant Engineer
DWS Sub-Division No-II,
Milon Sangha, Agartala.

No. F.2(1) /AE/DWS/SD-II /288

dated.04/09/2024

Ref: No. F.4 (05)/Principal/2023-24/151

To whom it may concern.

This is to certify that the water supply arrangement in Kabirajtilla H.S. School is very clean and quite satisfactory. The various parameters of drinking water as tested are within permissible limit.

This is issued in support of test report of water sample tested in the State Level water testing laboratory.

(Er.T.Choudhury)

Assistant Engineer,

DWS Sub-Division No-II,

Milon Sangha, Agartala.

Er.T.Choudhury
04/09/2024

Assistant Engineer
DWS Sub-Division No.-II
Milon Sangha, Agartala.

State Level Water Testing Laboratory

PWD(DWS), Government of Tripura
P.N. Complex,
Agartala - 799006
Mobile : 9402120089,
Website : www.dws.tripura.gov.in



TC-7350

TEST REPORT

Name & Address of the customer

H/M, Kabirajtilla HS School (A
Vidyajyoti School) Netaji Palli,
Badharghat, Water Sample from
Kabirajtilla HS School (A
Vidyajyoti School) Netaji Palli,
Badharghat, Tripura

Report No : SLWTL/2017/3413
Report Date : 02/09/2024
Sample ID : 3041UDL5YP
Date of Receipt of Sample : 31/08/2024, 12.15 pm
Date(s) of Performance : 02/09/2024
Ref. No. & Date : NIL

We hereby certify that the following sample submitted to the laboratory has been analyzed with the following results :

1.	Description of Sample (As declared by customer)	: Drinking Water
2.	Volume of Sample Received	: 500 ml
3.	Sample Mark (if any, given by the customer)	: NA
4.	Date of Sampling by the Customer	: 31/08/2024
5.	Source & Place of Sampling	: Water Sample from Kabirajtilla HS School (A Vidyajyoti School) Netaji Palli, Badharghat
6.	Environmental conditions during sampling	: NA
7.	Sampling Plan & Procedures used	: NA

Report Prepared by

Signature : 
Name : Samir Acharjee
Designation : Chemist

For State Level Water Testing Laboratory

Signature : 
Name : Sujoy Paul
Designation : Technical Manager
Authorized Signatory

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced except in full, without the permission of State Level Water Testing Laboratory
- The reserved part of sample(s) shall be retained for 15 days from the date of Completion of Test.

Contact Person : Er. Rajib Majumder,
Quality Manager, State Level Water Testing Laboratory
Mobile : 9402120089, Email : qmgtripura@gmail.com, Website : www.dws.tripura.gov.in

State Level Water Testing Laboratory

PWD(DWS), Government of Tripura
P.N. Complex,
Agartala - 799006
Mobile : 9402120089,
Website : www.dws.tripura.gov.in



TC-7350

Report No : SLWTL/2017/3413
Sample ID : 3041UDL5YP

Analysis of Result

SN	Characteristic	Acceptable Limit	Permissible Limit	Method of Test	Results
1	Turbidity in N.T.U	1	5	APHA 24th Edition 2130 B	0.46
2	pH value at 25°C	6.5-8.5	No Relaxation	APHA 24th Edition 4500-H+ B	6.52
3	Iron (as Fe) in mg/l	1.0	No Relaxation	APHA 24th Edition 3500-Fe B	BDL
4	Total Dissolved Solids in mg/l	500	2000	APHA 24th Edition 2540 C	14.2

BDL - Below Detection Level for Fluoride - <0.2 mg/l, Arsenic - <0.009 mg/l, Iron - <0.1 mg/l, Magnesium - <2 mg/l, Manganese - <0.01 mg/l/49">

Report Prepared by

Signature

Name : Samir Acharjee

Designation : Chemist

For State Level Water Testing Laboratory

Signature

Name : Sujoy Paul

Designation : Technical Manager

Authorized Signatory

-: End Of Report :-

Contact Person : Er. Rajib Majumder

Quality Manager, State Level Water Testing Laboratory,

Mobile : 9402120089, Email : qmgtripura@gmail.com, Website : www.dws.tripura.gov.in